

# COMPLIANCE SCHEDULE CHECKLIST

## Notes

Consultants must reference all appropriate procedures and address all specified systems and their performance standards when completing compliance schedules.

Address of property: \_\_\_\_\_

Consent ID: \_\_\_\_\_ Date received: \_\_\_\_\_

		CS	CL	CO	CM	WL	WM	WH	WF	IA	ID
There are no specified systems	<input type="radio"/>										

## Occupant load

	EXISTING	NEW	ALTERED	ADDED	REMOVED
Type of system	<input type="radio"/>				
Automatic systems for fire suppression (such as sprinklers)	<input type="radio"/>				
Electromagnetic doors or automatic doors or windows	<input type="radio"/>				
Automatic or manual emergency warning systems for fire or other danger	<input type="radio"/>				
Emergency lighting systems	<input type="radio"/>				
Escape route pressurisation systems	<input type="radio"/>				
Riser mains for use by fire services	<input type="radio"/>				
Any automatic backflow preventers fitted to a potable water supply	<input type="radio"/>				
Lifts, escalators, travelators, or other systems for moving people or goods	<input type="radio"/>				
Mechanical ventilation systems, or air conditioning systems	<input type="radio"/>				
Building maintenance units for providing access to buildings (internal or external)	<input type="radio"/>				
Laboratory fume cupboards	<input type="radio"/>				
Audio loops or other assistive listening devices	<input type="radio"/>				
Smoke control systems	<input type="radio"/>				
Emergency power systems for, or signs relating to, a system or feature specified in clauses 1-13 above.	<input type="radio"/>				
Any or all of the following systems and features, so long as they form part of a building's means of escape from fire and so long as those means also contain any or all of the systems or features specified in clause 1-6, 9 and 13					
a. Systems for communicating spoken information intended to facilitate evacuation	<input type="radio"/>				
b. Final exits (defined by A2 of New Zealand Building Code)	<input type="radio"/>				
c. Fire separations <sup>1</sup>	<input type="radio"/>				
d. Signs for communicating information intended to facilitate evacuation <sup>1</sup>	<input type="radio"/>				
e. Smoke separations	<input type="radio"/>				
All buildings with a cable car, including single residential buildings, require compliance schedule.	<input type="radio"/>				

<sup>1</sup>Fire separations and smoke separations become specified systems so long as they form part of a building's means of escape from fire